



FIRE SAFETY RISK ASSESSMENT
 To be carried out by responsible person in accordance with AD B Appendix 9 (as defined in the Regulatory Reform Order 2005) for the building on completion or first occupied.

FIRE LEGEND

- SD HD Smoke/Heat Detector
- E L P Emergency Lighting Luminaire (Pictographic)
- EL Emergency Lighting Luminaire
- N3 fire door - keep locked shut notice
- N5 fire exit - keep clear notice
- N7 fire door - keep shut notice
- A Alarm bell or Sounder
- B Break Glass Fire Alarm Point
- E 9 Kg Water Extinguisher
- A 6Kg Dry Powder Extinguisher
- FD30S Half Hour Fire Door Incorporating Intumescent Closing Device and Fire door keep shut sign N7.
- All external fire exits to have Fire Exit Keep Clear signs to external
- FIRE Automatic Fire Alarm Control Panel Plus Visual Indication
- All final exit doors to be operated by push bar/pad ironmongery.
- A Fire Blanket

Rev	Note	Initial	Date
T D JAGGER LTD			
CHARTERED BUILDING SURVEYORS PROJECT MANAGEMENT : DESIGN : DEVELOPMENT ADVICE			
		3 Richmond House Caldene Business Park Mytholmroyd Hebden Bridge West Yorkshire, HX7 5QJ enquiries@tdjagger.ltd.uk Tel: 01422 883317 www.tdjagger.ltd.uk Fax: 01422 883973	
Client OSCA			
Project Forest Cottage Cousin Lane Halifax, HX2 8AD			
Proposed Ground Floor Plan			
Drawing			
Date	Oct 18	Drawn	RL
Checked	Scale	1:50@A1	Scale
1798-18-10		B	
Drawing No.			
Revision			
Drawings are to scale indicated for planning purposes. No scaling permitted for construction purposes. Information on this drawing is copyright. All rights reserved. No part of this work may be reproduced or transmitted in any form by any means, either electronically, mechanically, by photocopying, recording or otherwise stored in any retrieval system of any nature, without the express consent of T D Jagger Ltd.		Don't Ignore Health & Safety It Might Just Save Your Life	